W-4554 - FIDUCIARY TRUST INTERNATIONAL
1 WTC - 95th FLOOR - GENERAL
CONSTRUCTION

WTC1-48-P

REVIEW STATUS

Sub-mission#	Response To #	Coordi-nator	TCRU Memo	Approval	Facility Rider	Outstanding Comments	Remarks
(7-11-90)	—	RAW	7-25-90	YES		2	Arch., Elect.

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

M E M O R A N D U M

To: Mr. Julian Kau, General Manager,
Planning, Design & Construction, WT&ED
From: Ennala Ramabhushanam
Date: July 25, 1990
Subject: **WTC - ALTERATION APPLICATION W-4554 - FIDUCIARY TRUST INTERNATIONAL - 1 WTC - 95TH FLOOR - GENERAL CONSTRUCTION**

Reference: Review Request dated 7/11/90

Copy To: G. Gaeta R. Wegel Job Folder
L. Menno Chrono Folder

A review of the material submitted with the referenced request for the subject application has been made.

It is recommended that approval to proceed with construction be given subject to the submission of the items listed below being revised in accordance with the two (2) requirements listed on the attached rider.

Drawings:

REMARKS: 1) Dwg. A-1, A-2 and A-3 dated 5/23/90, and Dwg. F-1-95, E-1, E-2 and E-3 dated 7/3/90, are recommended for approval.

2) This memorandum was transmitted to the Facility via OA, on July 25, 1990.

for Ennala Ramabhushanam, P.E.
Manager
Quality Assurance Division

RAW/dm
att.

[redacted]

RIDER

ALTERATION APPLICATION W-4554

ARCHITECTURAL

1. Dwg. A-1, Elevation 4. Verify that glass panels within 18" of finished floor comply with requirements of N.Y.C. Building Code, Section C26-1011.9, Table 10-9 and RS 10-67.

ELECTRICAL

2. Show source of emergency power (e.g. storage battery packs) for all exit signs, to establish compliance with N.Y.C. Building Code C26-606.2.

072590

7/11

TENANT ALTERATION REVIEW REQUEST

ROUTING	ROOM NO.
Quality Assurance	51N
Paul Cooper	
In House	74
Rick Sorvillo	
Charlie Semah	
Suren Batra	
R. Becker	
WT&EDD Construction	3861
P. Cavanaugh	
Operations	B-2B
Tom Cancelliere	
Risk Management	
John Foye (PATHSIDE)	4 FL
Asbestos	JSTO
Joseph Mullen	

Applicant's Name: FIDUCIARY TRUST INTERNATIONAL

Facility: WTC

Dwg. No(s).: See ATTACHED SHEET

T.A.A. No. 4554

Contract No. 592.068

Location: 1 WTC. 95TH | Date: 7-11-90

__Please review attached Application and forward comments to:

__Attached are revised drawings. Please review.

Org. Unit	Contact	Rm. No.	Ext.
829	S. Rosenberg	74S	766-2514

NOT LATER THAN: 7-25-90

G GAETA
Supervisor

If no reply is received by above date, your concurrence will be assumed unless arrangements have been made for additional time.

Description of Work: OPEN AREAS CLOSED TO PRIVATE AREAS

Construction Cost: $40,000.00

General Construction

- [x] Architectural
- [x] Electrical
- [x] HVAC
- [ ] Structural
- [x] Plumbing
- [x] Sprinkler
- [ ] Other _____

Submission No. 1

THE PORT AUTHORITY OF N.Y. & N.J.
TENANT CONSTRUCTION REVIEW UNIT
RECEIVED
JUL 12 1990
W-4554
ALTERATION APPLICATION

Office copy

cc: C. Bianchi, E. Daly, J. Kau, ~~M. LoPresti~~ G. GAETA, A. Preschle, G. Wenger, R. Wegel-,
Project Coordinator S. Rosenberg

Louis J. Menno — Title: Manager, Contract and Tenant Services Division — Date: 7/12/90

2/20/90

BONSIGNORE BRIGNATI & MAZZOTTA P.C. ARCHITECTS 275 SEVENTH AVENUE NEW YORK, NY 10001 212 633-1400

July 3, 1990

PROJECT 95-008
Fiduciary Trust International
Two World Trade Center
Fiduciary Financial Services

TITLE OF DRAWING	DWG. NO.	LATEST DUE
Construction/Demolition Plan	A-1	5/23/90
Reflected Ceiling Plan	A-2	5/23/90
Occupancy Plan	A-3	7/3/90
Sprinkler Plan	F-1-95	7/3/90
Power Plan	E-1	7/3/90
Lighting Plan	E-2	7/3/90
Electrical Specifications	E-3	7/3/90